

TEST REPORT

81701 / 1 S

Date received: 16-04-07
Date of test: 27-04-07
Date of issue: 14-05-12



CELEGON S.R.L.
VIA GALILEO GALILEI 6-Z.I.
30035 MIRANO (VE)
ITALIA

Sample name: Door provided with Ergon® series S/40 SYSTEM / Porta dotata del sistema rototraslante" ERGON® SERIE S 40"

Windows and doors. Repeated opening and closing EN 1191:2000

Type of door: with swinging sliding movement
Dimensions of the door: 790 x 40 x 2085 (height) mm
Weight of the door: 12 kg
Structural assembly of the door declared by the producer: Honeycomb panel thickness 40 mm
Structural assembly of the frame declared by the producer: Wooden door jamb
Hardware fitted: Magnetic lock
Opening angle: 90°
Test frequency: 4 cycles/min
Ambient temperature during the test: 20° C
Ambient humidity during the test: 50% U.R.



Test results:

Class of EN 12400:2002	Number of cycles	Cycles carried out	Deflection of the door mm	Opening - closing force initial (N)	Opening - closing force final (N)	Opening - closing force variation (%)
5	80.000	80.000	0,6	4,5	3,5	- 1

Note: on the same sample 20.000 cycles has been carried out before (see test report n° 78708 dated 09-03-07).

Description of "Ergon® series S/40 SYSTEM":

Aluminium guide permits the sliding movement of the door.
Superior and inferior plate permit the translation of the inside rod to the panel.
Superior and inferior arms permit the swinging sliding movement.
Special fixing brackets permit the fixing of the mechanism to the panel and to the jambs.

This document replaces the previous one with the same reference and with date of issue 30/05/07.

Head of Department
Paolo Balutto

Managing Director
Dr. Andrea Giavon

The sample name and, when relevant, its description, are given by the orderer, and CATAS does not assume responsibility on this matter. This test report relates to the sample submitted for the test and no others. Additions, deletions or alterations are not permitted. This test report must always be reproduced in its entirety. Unless otherwise stated, sampling has been carried out by the orderer.



centro ricerche-sviluppo
laboratorio prove settore legno-arredo

CATAS S.p.A.
C.F. - P.IVA:
IT 01818850305
Reg. Impr. Ud 20663
R.E.A. Ud 198012
Cap.Soc.: € 842.850 i.v.

Sede: Via Antica, 24/3
I - 33048 S. Giovanni al Natisone UD
Tel. 0432.747211 r.a.
Fax 0432.747250
<http://www.catas.com>
e-mail: lab@catas.com

Filiale:
Via Braille, 5
I - 20035 Lissone MI
Tel. 039.464567
Fax 039.464565
e-mail: lissone@catas.com

Date received: 16-04-07

Date of issue: 30-05-07

Report consists of 1 attached sheet.

CELEGON DI LAMON IVANO & C. S.A.S.
VIA GALILEO GALILEI 6-Z.I.
30035 MIRANO (VE)
ITALY

Sample name: Door provided with Ergon® series S/40 SYSTEM / Porta dotata del sistema rototraslante"
ERGON ® SERIE S 40"

TEST REPORT N° 81701

List performed tests

1. Windows and doors. Repeated opening and closing EN 1191:2000



Head of Department
Paolo Balutto

Managing Director
Dott. Andrea Giavon

Sample name is declared by the orderer. This report relates to the samples submitted for the test and no others. Additions, deletions or alterations are not permitted. This test report must always be reproduced in its entirety. Unless otherwise stated, sampling has been carried out by the orderer.